

Daycare Pre-Inspection Requirements

The following is a list of Fire Department Requirements to be completed before Fire Inspection.

1. 1-5lb or larger ABC Dry Chemical Fire Extinguisher shall be provided for daycare.
2. Outlet Covers for all outlets shall be provided.
3. Smoke Detectors shall be operational and shall be located in all sleeping areas and hallways.
4. A furnace inspection shall be completed if a gas furnace, not electric and paperwork of the service completed provided to fire dept.
5. Mobile Homes shall be newer than 1976 and have the ANSI label provided.
6. A Home Fire Escape plan shall be provided and posted.
7. Social Services shall be notified for their requirements.
8. A 10 Dollar fee for inspection shall be paid at the time of inspection.
9. If going to be group Planning and Zoning (433-5320) shall be contacted for their requirements.
10. An Egress window may be required for basement-depending on the house.
11. Basement shall be completely finished to have daycare.

These are the minimum requirements more may apply considering the home.

Should you have any questions or concerns please feel free to call me at the fire department at the number below. My card is also attached for further use.

Respectfully,

Kendel Frost

Fire Inspector